

G.N. 8700

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. FOK Shu Ming had failed to comply with regulation 19(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. FOK Shu Ming, being a registered electrical worker (Registration No. W112029), in or about November 2013, while carrying out electrical works in Flat 11, 2nd Floor, Career & Kenson Industrial Mansion, 58 Hung To Road, Kwun Tong, Kowloon failed to certify the fixed electrical installation after completion of alteration or addition and before it was energised for use.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. FOK Shu Ming.

13 November 2015

LAI Hon-chung for *Director of Electrical and Mechanical Services*