

G.N. 382

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. LI Yee Yan had failed to comply with Regulation 19(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. LI Yee Yan, being a registered electrical worker (Registration No. W101662), in or about November 2014, failed to certify the fixed electrical installation at Room 23, 7th Floor, Yau Shing House, May Shing Court, Tai Wai, New Territories after completion of alteration and before it was energised for use.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. LI Yee Yan.

22 January 2016

LAI Hon-chung for *Director of Electrical and Mechanical Services*