

**G.N. 1549**

**ELECTRICITY ORDINANCE (Chapter 406)**

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I am satisfied on evidence and have decided that Mr. SO Long Yin had failed to comply with Regulation 19(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. SO Long Yin, being a registered electrical worker (Registration No. W100407), on or about 4 December 2013, in Flat B, 12th Floor, Hoi Ying Building, 29 King's Road, North Point, Hong Kong, failed to certify the fixed electrical installation after completion of repair and before it was energised for use to confirm that the requirements of the Ordinance had been met.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. SO Long Yin.

*18 March 2016*

LAI Hon-chung for *Director of Electrical and Mechanical Services*