

G.N. 5102

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. MAK Kan Lee had failed to comply with Regulation 19(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. MAK Kan Lee, being a registered electrical worker (Registration No. W008784), between 1 December 2013 and 2 February 2015, carried out electrical work at Shop B, Ground Floor, No. 82 Wing Kwong Street, To Kwa Wan, Kowloon but failed to certify the fixed electrical installation after completion and before it was energised for use to confirm that the requirements of the Ordinance had been met.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. MAK Kan Lee.

9 September 2016

LAI Hon-chung for *Director of Electrical and Mechanical Services*