

G.N. 7273

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. LEUNG Si Yiu had failed to comply with Regulation 21(4) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. LEUNG Si Yiu, being a registered electrical worker (Registration No. W034842), on or about 11 October 2014, at The Plaza LKF, No. 21 D'Aguilar Street, Central, Hong Kong, failed to ensure that the tests and inspections covered in his certificate for the fixed electrical installation had been carried out.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. LEUNG Si Yiu.

23 December 2016

LAI Hon-chung for *Director of Electrical and Mechanical Services*