

**G.N. 7274**

**ELECTRICITY ORDINANCE (Chapter 406)**

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I am satisfied on evidence and have decided that Mr. LEE Yau Choi had failed to comply with Regulation 19(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. LEE Yau Choi, being a registered electrical worker (Registration No. W037428), on or about 31 December 2014, in Shop 3, Ground Floor, Po Wah Court, Nos. 450–464 Un Chau Street, Kowloon, failed to certify the fixed electrical installation after completion and before it was energised for use to confirm that the requirements of the Ordinance had been met.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. LEE Yau Choi.

23 December 2016

LAI Hon-chung for *Director of Electrical and Mechanical Services*