

G.N. 6687

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Kiu Hung Water & Electrical & Air-conditioning Works Co had failed to comply with regulation 21(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Kiu Hung Water & Electrical & Air-conditioning Works Co, being a registered electrical contractor (Registration No.: 002171), on or about 30 June 2016, was responsible for the electrical work at Stall No. SS12, Ma On Terrace Chinese Market, Kam Ying Court, Ma On Shan, New Territories but failed to carry out tests on the fixed electrical installation at the aforesaid stall with proper tools and testing equipment.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Kiu Hung Water & Electrical & Air-conditioning Works Co.

8 September 2017

LAI Hon-chung for *Director of Electrical and Mechanical Services*