

G.N. 9732

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. CHAN Kwong-cheung had failed to comply with Regulation 19(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. CHAN Kwong-cheung, being a registered electrical worker (Registration No.: W032411), on 11 November 2015 and 9 March 2016, at Flat B, 1st Floor., On Fat Industrial Building, Nos. 12–18 Kwai Wing Road, Kwai Chung, New Territories, failed to certify the fixed electrical installation after repair and before it is energized for use.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. CHAN Kwong-cheung.

22 December 2017

LAI Hon-chung for *Director of Electrical and
Mechanical Services*