

**G.N. 9734**

**ELECTRICITY ORDINANCE (Chapter 406)**

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. KWOK Chi-fai had failed to comply with the Regulation 21(4) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. KWOK Chi-fai, being a registered electrical worker (Registration No.: W056056), on or about 17 July 2013, failed to ensure that the insulation resistance tests covered in the periodic test certificate for Lee Fung Building, 88-96 Argyle Street/104 Hak Po Street/19 Yim Po Fong Street, Mong Kok, Kowloon, had been carried out.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. KWOK Chi-fai.

22 December 2017

LAI Hon-chung for *Director of Electrical and  
Mechanical Services*