

**G.N. 2596**

**ELECTRICITY ORDINANCE (Chapter 406)**

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Fat Kee Electrical & Water Works Limited had failed to comply with Regulation 19(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Fat Kee Electrical & Water Works Limited, being a registered electrical contractor (Registration No.: 028624), on or about 27 May 2017, was responsible for the electrical work at 2nd Floor, 173 Kwan Tei, Fanling, New Territories but failed to ensure that the fixed electrical installation, after completion and before it was energised for use, had been certified by a registered electrical worker to confirm that the requirements of the Ordinance had been met.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Fat Kee Electrical & Water Works Limited.

*13 April 2018*

*POON Kwok-ying for Director of Electrical  
and Mechanical Services*