

G.N. 2818

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Idea Green Engineering Company Limited had failed to comply with the regulation 12(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Idea Green Engineering Company Limited, being a registered electrical contractor (Registration No.: 028581), between August and September 2016, was responsible for the electrical work at Hawker Stall Nos. 104, 106, 111, 112, 116 and 117, Bowring Street, Yau Ma Tei, Kowloon but failed to ensure that the earthing conductor was connected to earth electrode.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Idea Green Engineering Company Limited.

26 April 2019

VY Ek-chin for *Director of Electrical and Mechanical Services*