

G.N. 3128

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. Fan Wai Chee had failed to comply with Regulation 4(3) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. Fan Wai Chee, being a registered electrical worker (Registration No. W017797), on or about 12 July 2011, while carrying out electrical work at Sheung Shui Town Center, No. 9 Chi Cheong Road, Sheung Shui, New Territories, incorrectly labeled the air circuit breaker numbers and hence failed to ensure that the electrical equipment shall be installed so that it is capable of being identified, maintained, inspected and tested so as to prevent danger.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. Fan Wai Chee.

10 May 2019

VY Ek-chin for *Director of Electrical and Mechanical Services*