

**G.N. 3129**

**ELECTRICITY ORDINANCE (Chapter 406)**

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I am satisfied on evidence and have decided that Kin Fung Engineering Limited had failed to comply with Regulation 5(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Kin Fung Engineering Limited, being a registered electrical contractor (Registration No. 023672), on or about 26 November 2013, failed to ensure that Category 1, 2, 3 and 4 circuits shall be segregated from one another as far as is necessary to prevent danger and electrical interference in Kellett School, 7 Lam Hing Street, Kowloon Bay, Kowloon.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Kin Fung Engineering Limited.

*10 May 2019*

VY Ek-chin for *Director of Electrical and Mechanical Services*