

G.N. 3231

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Wecon Construction & Engineering Limited had failed to comply with Regulation 4(3) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Wecon Construction & Engineering Limited, being a registered electrical contractor (Registration No. 026425), on or about 19 July 2017, while carrying out electrical work in a construction site at 43-45 Tsun Yip Street, Kwun Tong, Kowloon failed to ensure that the proper labels for the fixed electrical installation and the Notice of Testing for Residual Current Devices were installed so that it is capable of being identified, maintained, inspected and tested, where appropriate, so as to prevent danger.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Wecon Construction & Engineering Limited.

17 May 2019

VY Ek-chin for *Director of Electrical and
Mechanical Services*