

G.N. 3233

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. LAW Hon-sing had failed to comply with regulation 21(4) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. LAW Hon-sing, being a registered electrical worker (Registration No.: W111933), on 15 July 2016, issued a work completion certificate for the fixed electrical installation at Shop B, Ground Floor, No. 16 Cameron Road, Tsim Sha Tsui, Kowloon but failed to carry out earth fault loop impedance tests for the circuits of the installation.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. LAW Hon-sing.

17 May 2019

VY Ek-chin for *Director of Electrical and
Mechanical Services*