

G.N. 4328

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. CHING Hok Mo had failed to comply with Regulation 11(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. CHING Hok Mo, being a registered electrical worker (Registration No. W015618), on or about 20 November 2015, at Ning Yeung Terrace, No. 78 Bonham Road, Central, Hong Kong, failed to provide a circuit with effective means to prevent the persistence of earth fault currents and dangerous earth leakage currents.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. CHING Hok Mo.

5 July 2019

VY Ek-chin for *Director of Electrical and Mechanical Services*