

G.N. 4329

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Prestige Construction & Engineering Co. Limited had failed to comply with Regulation 11(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Prestige Construction & Engineering Co. Limited, being a registered electrical contractor (Registration No. 021057), on or about 20 November 2015, at Ning Yeung Terrace, No. 78 Bonham Road, Central, Hong Kong, failed to provide a circuit with effective means to prevent the persistence of earth fault currents and dangerous earth leakage currents.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Prestige Construction & Engineering Co. Limited.

5 July 2019

VY Ek-chin for *Director of Electrical and Mechanical Services*