

G.N. 5166

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. CHAN Hak Cheng had failed to comply with Regulation 19(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. CHAN Hak Cheng, being a registered electrical worker (Registration No. W062148), on or about 11 September 2017, while carrying out electrical works in Flat 2704, King Tai Court, San Po Kong, Kowloon failed to certify the fixed electrical installation after completion of alteration or addition and before it was energised for use to confirm that the requirements of the Ordinance had been met.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. CHAN Hak Cheng.

16 August 2019

VY Ek-chin for *Director of Electrical and Mechanical Services*