

G.N. 5271

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. PANG Man-wai had failed to comply with the Regulation 19(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. PANG Man-wai, being a registered electrical worker (Registration No.: W001356), on or about August 2017, at the Construction site, Tin Shui Wai Town Lot 34, Tin Shui Wai, New Territories, failed to conduct testing with relevant metres and certify the electrical work after completion of the work for temporary power supply to confirm that the requirements of the Ordinance had been met.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. PANG Man-wai.

23 August 2019

VY Ek-chin for *Director of Electrical and Mechanical Services*