

G.N. 5272

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. LEUNG Man-lun had failed to comply with Regulation 21(2) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. LEUNG Man-lun, being a registered electrical worker (Registration No.: W063472), between March and April 2015, did electrical work for Pitch Nos. 314, 179, 180, 181, 184 and 185, Apliu Street, Kowloon, but failed to record the result of earth fault loop impedance test and date the inspection result.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. LEUNG Man-lun.

23 August 2019

VY Ek-chin for *Director of Electrical and Mechanical Services*