

**G.N. 5273**

**ELECTRICITY ORDINANCE (Chapter 406)**

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ("the Ordinance"), I was satisfied on evidence and decided that Ascott Engineering Limited had failed to comply with the Regulation 22(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Ascott Engineering Limited, being a registered electrical contractor (Registration No.: 028124), on or about April 2015, was responsible for the electrical work at Pitch Nos. 314, 179, 180, 181, 184 and 185, Apliu Street, Kowloon, but failed to keep all relevant testing records.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Ascott Engineering Limited.

23 August 2019

VY Ek-chin for *Director of Electrical and Mechanical Services*