

**G.N. 5275**

**ELECTRICITY ORDINANCE (Chapter 406)**

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. YIP Wai-leung had failed to comply with the Regulation 21(4) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. YIP Wai-leung, being a registered electrical worker (Registration No.: W053039), on or about 25 January 2017, responsible for the electrical work at Kin Ga Court, 207 Yee Kuk Street, Sham Shui Po, Kowloon, but failed to ensure that the results of the secondary injection test covered in his test certificate were satisfactory.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Mr. YIP Wai-leung.

23 August 2019

VY Ek-chin for *Director of Electrical and Mechanical Services*