

G.N. 5609

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Mr. YU Siu Cheung had failed to comply with regulation 4(7) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Mr. YU Siu Cheung, being a registered electrical worker (Registration No. : W018861), on 4 March 2017, at the Meter Room at Corridor near Room 214, 2nd Floor, Fook Wo House, Tai Wo Estate, Tai Po, New Territories, failed to ensure that safety precautions had been taken to prevent danger arising from electrical wiring work done by him or under his supervision, resulting in the occurrence of an incident of cable damage and electricity supply interruption.

It is further notified that in accordance with section 36(1)(b) of the Ordinance, I have reprimanded and fined Mr. YU Siu Cheung \$500.

6 September 2019

LAI Hon-chung for *Director of Electrical and Mechanical Services*