

淨劑滅火器
CLEAN AGENT TYPE EXTINGUISHERS

Ansul Inc., 1 Stanton Street, Marinette, WI 54143, U.S.A.

Model: CA-0681 Size: 2.73 kilogram Fire Rating: 5B:C (Approval Expiry Date: 1.1.2026)

Model: CA-1081 Size: 4.55 kilogram Fire Rating: 1A:10B:C (Approval Expiry Date: 1.1.2026)

Model: CA-1481 Size: 6.36 kilogram Fire Rating: 2A:10B:C (Approval Expiry Date: 1.1.2026)

Model: FE02 Size: 1.14 kilogram Fire Rating: 2B:C (Approval Expiry Date: 1.1.2026)

Model: FE05 Size: 2.16 kilogram Fire Rating: 5B:C (Approval Expiry Date: 1.1.2026)

Model: FE09 Size: 4.32 kilogram Fire Rating: 1A:10B:C (Approval Expiry Date: 1.1.2026)

Model: FE13 Size: 6.02 kilogram Fire Rating: 2A:10B:C (Approval Expiry Date: 1.1.2026)

Model: FE13NM Size: 6.02 kilogram Fire Rating: 1A:10B:C (Approval Expiry Date: 1.1.2026)

BSCO, Inc., 343-B, Granary Road, Forest Hill, MD 21050, U.S.A.

Model: M740-900 Max. Protected Volume 25.5m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-100 Max. Protected Volume 2.8m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-1000 Max. Protected Volume 28.3m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-1100 Max. Protected Volume 31.1m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-1200 Max. Protected Volume 34m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-125 Max. Protected Volume 3.5m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-1300 Max. Protected Volume 36.8m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-1400 Max. Protected Volume 39.6m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-150 Max. Protected Volume 4.2m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-1500 Max. Protected Volume 42.5m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-200 Max. Protected Volume 5.7m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-250 Max. Protected Volume 7.1m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-300 Max. Protected Volume 8.5m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-350 Max. Protected Volume 9.9m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Model: MA740-400 Max. Protected Volume 11.3m³ Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

Model: MA740-450 Max.	Protected Volume	12.7m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: MA740-50 Max.	Protected Volume	1.4m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: MA740-500 Max.	Protected Volume	14.2m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: MA740-550 Max.	Protected Volume	15.6m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: MA740-600 Max.	Protected Volume	17m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: MA740-650 Max.	Protected Volume	18.4m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: MA740-700 Max.	Protected Volume	19.8m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: MA740-75 Max.	Protected Volume	2.1m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: MA740-750 Max.	Protected Volume	21.2m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: MA740-800 Max.	Protected Volume	22.7m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: MA740-900 Max.	Protected Volume	25.5m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-450 Max.	Protected Volume	12.7m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-50 Max.	Protected Volume	1.4m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-500 Max.	Protected Volume	14.2m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-550 Max.	Protected Volume	15.6m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-600 Max.	Protected Volume	17m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-650 Max.	Protected Volume	18.4m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-700 Max.	Protected Volume	19.8m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-75 Max.	Protected Volume	2.1m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-750 Max.	Protected Volume	21.2m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-800 Max.	Protected Volume	22.7m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-100 Max.	Protected Volume	2.8m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-1000 Max.	Protected Volume	28.3m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-125 Max.	Protected Volume	3.5m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-150 Max.	Protected Volume	4.2m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-200 Max.	Protected Volume	5.7m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-250 Max.	Protected Volume	7.1m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-300 Max.	Protected Volume	8.5m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-350 Max.	Protected Volume	9.9m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

Model: A740-400	Max. Protected Volume	11.3m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-450	Max. Protected Volume	12.7m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-50	Max. Protected Volume	1.4m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-500	Max. Protected Volume	14.2m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-550	Max. Protected Volume	15.6m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-600	Max. Protected Volume	17m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-650	Max. Protected Volume	18.4m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-700	Max. Protected Volume	19.8m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-75	Max. Protected Volume	2.1m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-750	Max. Protected Volume	21.2m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-800	Max. Protected Volume	22.7m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: A740-900	Max. Protected Volume	25.5m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-100	Max. Protected Volume	2.8m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-1000	Max. Protected Volume	28.3m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-1100	Max. Protected Volume	31.1m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-1200	Max. Protected Volume	34m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-125	Max. Protected Volume	3.5m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-1300	Max. Protected Volume	36.8m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-1400	Max. Protected Volume	39.6m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-150	Max. Protected Volume	4.2m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-1500	Max. Protected Volume	42.5m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-200	Max. Protected Volume	5.7m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-250	Max. Protected Volume	7.1m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-300	Max. Protected Volume	8.5m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-350	Max. Protected Volume	9.9m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)
Model: M740-400	Max. Protected Volume	11.3m ³	Remark: Dupont FE-227 (Approval Expiry Date: 1.1.2026)

Ceasefire Industries Limited, 2nd Floor, Plot No. 4, Sector -135, Noida, Uttar Pradesh, 201 301, India

Model: CF 000705 Stored Pressure Type Size: 2 kilogram Fire Rating: 21B (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

Model: CF 000706 Stored Pressure Type Size: 4 kilogram Fire Rating: 21B (Approval Expiry Date: 1.1.2026)

Model: CF 000707 Stored Pressure Type Size: 6 kilogram Fire Rating: 34B (Approval Expiry Date: 1.1.2026)

Model: CF 000708 Stored Pressure Type Size: 9 kilogram Fire Rating: 55B (Approval Expiry Date: 1.1.2026)

Consolidated Marine Products, Inc., Fireboy Division, 100, Commerce Avenue, SW, Grand Rapids, Michigan 49503, U.S.A.

Model: CG2 Remark: FM-200, Serial No. 025-1000 (Approval Expiry Date: 1.1.2026)

Model: MA2 Remark: FM-200, Serial No. 025-1500 (Approval Expiry Date: 1.1.2026)

Fireboy-Xintex, Inc., O-379 Lake Michigan Dr., Grand Rapids, MI 49544

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG2-025 through-1000-227 Stored Pressure Type HFC-227ea Remark: All CG2 Model Numbers refer to the volume that can be protected (in cubic feet) with an 8.3 percent concentration of HFC-227ea Clean Agent (Approval Expiry Date: 1.1.2026)

Fireboy Manual- Automatic (MA2 Series) Fire Extinguishing Systems Model: MA2-025 through-1500-227 Stored Pressure Type HFC-227ea Remark: All MA2 Model Numbers refer to the volume that can be protected (in cubic feet) with an 8.3 percent concentration of HFC-227ea Clean Agent (Approval Expiry Date: 1.1.2026)

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20025227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 0.7 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20050227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 1.4 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20075227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 2.1 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20100227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 2.8 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20125227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 3.5 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20150227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 4.3 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20175227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 4.9 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20200227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 5.7 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20225227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 6.4 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20250227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 7.0 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20275227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 7.8 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20300227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 8.5 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20325227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 9.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20350227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 10.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20375227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 10.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20400227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 11.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20450227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 12.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20500227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 14.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20550227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 15.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20600227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 17.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20650227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 18.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20700227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 19.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20750227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 21.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20800227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 22.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20850227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 24.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20900227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 25.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20950227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 26.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG21000227-BXXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 28.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20025227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 0.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20050227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 1.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20075227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 2.1 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20100227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 2.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20125227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 3.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20150227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 4.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20175227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 4.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20200227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 5.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20225227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 6.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20250227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 7.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20275227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 7.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20300227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 8.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20325227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 9.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20350227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 10.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20375227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 10.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20400227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 11.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20450227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 12.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20500227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 14.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20550227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 15.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20600227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 17.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20650227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 18.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20700227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 19.8 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20750227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 21.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20800227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 22.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20850227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 24.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20900227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 25.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20950227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 26.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21000227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 28.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21050227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 29.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21100227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 31.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21150227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 33.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21200227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 34.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21250227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 35.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21300227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 36.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21350227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 38.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21400227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 39.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21450227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 41.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21500227-BLXXX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 42.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20025227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 0.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20050227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 1.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20075227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 2.1 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20100227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 2.8 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20125227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 3.5 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20150227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 4.3 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20175227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 4.9 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20200227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 5.7 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20225227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 6.4 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20250227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 7.0 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20275227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 7.8 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20300227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 8.5 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20325227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 9.2 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20350227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 10.0 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20375227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 10.6 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20400227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 11.3 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20450227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 12.7 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20500227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 14.1 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20550227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 15.6 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20600227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 17.0 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20650227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 18.4 cubic meter (Approval Expiry Date: 1.1.2026)
Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20700227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 19.8 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20750227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 21.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20800227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 22.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20850227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 24.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20900227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 25.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG20950227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 26.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG2 Series) Fire Extinguishing Systems Model: CG21000227-B30XX Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 28.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20025227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 0.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20050227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 1.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20075227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 2.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20100227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 2.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20125227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 3.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20150227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 4.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20175227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 4.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20200227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 5.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20225227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 6.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20250227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 7.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20275227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 7.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20300227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 8.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20325227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 9.2 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20350227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 10.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20375227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 10.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20400227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 11.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20450227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 12.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20500227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 14.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20550227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 15.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20600227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 17.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20650227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 18.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20700227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 19.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20750227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 21.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20800227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 22.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20850227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 24.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20900227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 25.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA20950227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 26.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21000227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 28.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21050227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 29.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21100227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 31.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21150227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 33.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21200227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 34.0 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21250227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 35.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21300227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 36.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21350227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 38.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21400227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 39.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21450227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 41.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA2 Series) Fire Extinguishing Systems Model: MA21500227-BL30X Stored Pressure Type HFC-227ea Remark: Class B Fire only; Volume protected: 42.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0025NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 0.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0050NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 1.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0075NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 2.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0100NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 2.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0125NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 3.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0150NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 4.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0175NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 4.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0200NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 5.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0225NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 6.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0250NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 7.0 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0275NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 7.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0300NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 8.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0325NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 9.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0350NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 10.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0375NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 10.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0400NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 11.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0450NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 12.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0500NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 14.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0550NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 15.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0600NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 17.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0650NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 18.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0700NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 19.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0750NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 21.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0800NVC-XXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 22.6 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0850NVC-XXXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 24.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0900NVC-XXXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 25.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0950NVC-XXXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 26.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG1000NVC-XXXXXX (Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 28.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0025NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 0.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0050NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 1.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0075NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 2.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0100NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 2.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0125NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 3.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0150NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 4.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0175NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 4.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0200NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 5.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0225NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 6.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0250NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 7.0 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0275NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 7.8 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0300NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 8.5 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0325NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 9.2 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0350NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 10.0 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0375NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 10.6 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0400NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 11.3 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0450NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 12.7 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0500NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 14.1 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0550NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 15.6 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0600NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 17.0 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0650NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 18.4 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0700NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 19.8 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0750NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 21.2 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0800NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 22.6 cubic
meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0850NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 24.0 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0900NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 25.5 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0950NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 26.9 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1000NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 28.3 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1050NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 29.7 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1100NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 31.1 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1150NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 33.0 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1200NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 34.0 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1250NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 35.4 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1300NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 36.8 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1350NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 38.2 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1400NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 39.6 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1450NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 41.0 cubic
meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1500NVC-XXXXXX (Manual / Automatic 175° F) Stored Pressure Type
Clean Agent “Novoc 1230” Remark: Class B Fire only; Volume protected: 42.5 cubic
meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA1550NVC-XXXXXX (Manual / Automatic 175° F) Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 43.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA1600NVC-XXXXXX (Manual / Automatic 175° F) Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 45.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA1650NVC-XXXXXX (Manual / Automatic 175° F) Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 46.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA1700NVC-XXXXXX (Manual / Automatic 175° F) Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 48.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA1750NVC-XXXXXX (Manual / Automatic 175° F) Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 49.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA1800NVC-XXXXXX (Manual / Automatic 175° F) Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 51.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0025NVC-30XXX (Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 0.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0050NVC-30XXX (Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 1.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0075NVC-30XXX (Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 2.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0100NVC-30XXX (Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 2.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0125NVC-30XXX (Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 3.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0150NVC-30XXX (Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 4.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0175NVC-30XXX (Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 4.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0200NVC-30XXX (Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 5.7 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0225NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 6.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0250NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 7.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0275NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 7.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0300NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 8.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0325NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 9.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0350NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 10.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0375NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 10.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0400NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 11.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0450NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 12.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0500NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 14.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0550NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 15.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0600NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 17.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0650NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 18.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0700NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 19.8 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0750NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 21.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0800NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 22.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0850NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 24.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0900NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 25.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG0950NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 26.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Automatic (CG Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: CG1000NVC-30XXX (Automatic 155 F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 28.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0025NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 0.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0050NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 1.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0075NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 2.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0100NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 2.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0125NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 3.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0150NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 4.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0175NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 4.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit) Model: MA0200NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 5.7 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0225NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 6.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0250NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 7.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0275NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 7.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0300NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 8.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0325NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 9.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0350NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 10.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0375NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 10.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0400NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 11.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0450NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 12.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0500NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 14.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0550NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 15.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0600NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 17.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0650NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 18.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0700NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novec 1230” Remark: Class B Fire only; Volume protected: 19.8 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0750NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 21.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0800NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 22.6 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0850NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 24.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0900NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 25.5 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA0950NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 26.9 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1000NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 28.3 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1050NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 29.7 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1100NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 31.1 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1150NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 33.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1200NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 34.0 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1250NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 35.4 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1300NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 36.8 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1350NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 38.2 cubic meter (Approval Expiry Date: 1.1.2026)
- Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1400NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 39.6 cubic meter (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1450NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 41.0 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1500NVC-30XXX (Manual / Automatic 155° F) Stored Pressure Type Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 42.5 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1550NVC-30XXX (Manual / Automatic 155° F) Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 43.9 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1600NVC-30XXX (Manual / Automatic 155° F) Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 45.3 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1650NVC-30XXX (Manual / Automatic 155° F) Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 46.7 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1700NVC-30XXX (Manual / Automatic 155° F) Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 48.1 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1750NVC-30XXX (Manual / Automatic 155° F) Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 49.6 cubic meter (Approval Expiry Date: 1.1.2026)

Fireboy Manual-Automatic (MA Series) Clean Agent Fire Extinguishers (Fixed Spray Unit)
Model: MA1800NVC-30XXX (Manual / Automatic 155° F) Clean Agent “Novac 1230” Remark: Class B Fire only; Volume protected: 51.0 cubic meter (Approval Expiry Date: 1.1.2026)

Incontrol Systems Inc., Unit 5, 28 Fulton Way, Richmond Hill, Ontario, L4B 1J5, Canada

Torrent Series Automatic Extinguisher Model: SFS-06 Stored Pressure Type HFC-227ea
Size: 2.7 kilogram Max. Protected Volume Class A&C Fires: 3.9m³; Class B Fire: 3.9m³
(Approval Expiry Date: 1.1.2026)

Torrent Series Automatic Extinguisher Model: SFM-07 Stored Pressure Type HFC-227ea
Size: 3.2 kilogram Max. Protected Volume Class A&C Fires: 5.8m³; Class B Fire: 4.6m³
(Approval Expiry Date: 1.1.2026)

Torrent Series Automatic Extinguisher Model: SFM-09 Stored Pressure Type HFC-227ea
Size: 4.1 kilogram Max. Protected Volume Class A&C Fires: 7.5m³; Class B Fire: 5.9m³
(Approval Expiry Date: 1.1.2026)

Torrent Series Automatic Extinguisher Model: SFM-12 Stored Pressure Type HFC-227ea
Size: 5.5 kilogram Max. Protected Volume Class A&C Fires: 7.9m³; Class B Fire: 7.9m³
(Approval Expiry Date: 1.1.2026)

Torrent Series Automatic Extinguisher Model: SFL-15 Stored Pressure Type HFC-227ea
Size: 6.8 kilogram Max. Protected Volume Class A&C Fires: 12.5m³; Class B Fire: 9.8m³
(Approval Expiry Date: 1.1.2026)

Torrent Series Automatic Extinguisher Model: SFL-20 Stored Pressure Type HFC-227ea
Size: 9.1 kilogram Max. Protected Volume Class A&C Fires: 15.7m³; Class B Fire: 13.1m³
(Approval Expiry Date: 1.1.2026)

Torrent Series Automatic Extinguisher Model: SFL-24 Stored Pressure Type HFC-227ea
Size: 10.9 kilogram Max. Protected Volume Class A&C Fires: 15.7m³; Class B Fire: 15.7m³ (Approval Expiry Date: 1.1.2026)

Torrent Series Automatic Extinguisher Model: SFX-31 Stored Pressure Type HFC-227ea
Size: 13.6 kilogram Max. Protected Volume Class A&C Fires: 25.8m³; Class B Fire: 20.3m³ (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

Torrent Series Automatic Extinguisher Model: SFX-36 Stored Pressure Type HFC-227ea
 Size: 15.9 kilogram Max. Protected Volume Class A&C Fires: 27.6m³; Class B Fire:
 23.6m³ (Approval Expiry Date: 1.1.2026)

Torrent Series Automatic Extinguisher Model: SFX-42 Stored Pressure Type HFC-227ea
 Size: 19.1 kilogram Max. Protected Volume Class A&C Fires: 27.6m³; Class B Fire:
 27.6m³ (Approval Expiry Date: 1.1.2026)

Sea-Fire Extinguishing Marine products, Division of Metalcraft, Inc., 9331A Philadelphia Road,
 Baltimore, Maryland 21237, U.S.A.

Model: C100 Size: 4.89 kilogram Fire Rating: 5B:C Remark: FM-200 (Approval Expiry
 Date: 1.1.2026)

Model: C20 Size: 1.25 kilogram Fire Rating: 2B:C Remark: FM-200 (Approval Expiry
 Date: 1.1.2026)

Model: C50 Size: 2.61 kilogram Fire Rating: 5B:C Remark: FM-200 (Approval Expiry
 Date: 1.1.2026)

Model: FD1000 Size: 18.5 kilogram Max. Protected Volume 28.3m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD1100 Size: 20.45 kilogram Max. Protected Volume 31.1m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD1200 Size: 22.27 kilogram Max. Protected Volume 33.9m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD1300 Size: 24.09 kilogram Max. Protected Volume 36.8m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD1400 Size: 25.91 kilogram Max. Protected Volume 39.6m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD150 Size: 2.68 kilogram Max. Protected Volume 4.2m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD1500 Size: 27.73 kilogram Max. Protected Volume 42.5m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD200 Size: 3.55 kilogram Max. Protected Volume 5.7m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD250 Size: 4.45 kilogram Max. Protected Volume 7.1m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD300 Size: 5.55 kilogram Max. Protected Volume 8.5m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD350 Size: 6.45 kilogram Max. Protected Volume 9.9m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD400 Size: 7.41 kilogram Max. Protected Volume 11.3m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD450 Size: 8.32 kilogram Max. Protected Volume 12.7m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD500 Size: 9.23 kilogram Max. Protected Volume 14.2m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD600 Size: 11.09 kilogram Max. Protected Volume 17m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD700 Size: 12.95 kilogram Max. Protected Volume 19.8m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD800 Size: 14.77 kilogram Max. Protected Volume 22.7m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FD900 Size: 16.64 kilogram Max. Protected Volume 25.5m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FG100 Size: 1.73 kilogram Max. Protected Volume 2.8m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FG125 Size: 2.18 kilogram Max. Protected Volume 3.5m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

Model: FG150 Size: 2.59 kilogram Max. Protected Volume 4.2m³ Remark: FM-200
 (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- Model: FG175 Size: 3.05 kilogram Max. Protected Volume 5m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)
- Model: FG200 Size: 3.45 kilogram Max. Protected Volume 5.7m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)
- Model: FG225 Size: 3.86 kilogram Max. Protected Volume 6.4m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)
- Model: FG50 Size: 0.86 kilogram Max. Protected Volume 1.4m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)
- Model: FG75 Size: 1.32 kilogram Max. Protected Volume 2.1m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)

Sea-Fire Marine, Division of Metalcraft, Inc., 9331A Philadelphia Rd., Baltimore, MD 21237, USA

- 'FIRE-HAWK' Model: NFG 50 A M Stored Pressure Type NOVEC 1230 Size: 1.72 litre Max. Protected Volume 1.4m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFG 75 A M Stored Pressure Type NOVEC 1230 Size: 1.72 litre Max. Protected Volume 2.1m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFG 100 A M Stored Pressure Type NOVEC 1230 Size: 2.23 litre Max. Protected Volume 2.8m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFG 125 A M Stored Pressure Type NOVEC 1230 Size: 4.1 litre Max. Protected Volume 3.5m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFG 150 A M Stored Pressure Type NOVEC 1230 Size: 4.1 litre Max. Protected Volume 4.2m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFG 175 A M Stored Pressure Type NOVEC 1230 Size: 4.1 litre Max. Protected Volume 5m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFG 200 A M Stored Pressure Type NOVEC 1230 Size: 4.1 litre Max. Protected Volume 5.7m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 225 A M Stored Pressure Type NOVEC 1230 Size: 6.23 litre Max. Protected Volume 6.4m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 250 A M Stored Pressure Type NOVEC 1230 Size: 6.23 litre Max. Protected Volume 7.1m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 275 A M Stored Pressure Type NOVEC 1230 Size: 6.23 litre Max. Protected Volume 7.8m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 300 A M Stored Pressure Type NOVEC 1230 Size: 6.23 litre Max. Protected Volume 8.5m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 325 A M Stored Pressure Type NOVEC 1230 Size: 8.52 litre Max. Protected Volume 9.2m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 350 A M Stored Pressure Type NOVEC 1230 Size: 8.52 litre Max. Protected Volume 9.9m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 375 A M Stored Pressure Type NOVEC 1230 Size: 8.52 litre Max. Protected Volume 10.6m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 400 A M Stored Pressure Type NOVEC 1230 Size: 8.52 litre Max. Protected Volume 11.3m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- 'FIRE-HAWK' Model: NFD 425 A M Stored Pressure Type NOVEC 1230 Size: 10.65 litre
Max. Protected Volume 12m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 450 A M Stored Pressure Type NOVEC 1230 Size: 10.65 litre
Max. Protected Volume 12.7m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 475 A M Stored Pressure Type NOVEC 1230 Size: 10.65 litre
Max. Protected Volume 13.4m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 500 A M Stored Pressure Type NOVEC 1230 Size: 10.65 litre
Max. Protected Volume 14.2m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 525 A M Stored Pressure Type NOVEC 1230 Size: 10.65 litre
Max. Protected Volume 14.9m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 550 A M Stored Pressure Type NOVEC 1230 Size: 13.93 litre
Max. Protected Volume 15.6m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 575 A M Stored Pressure Type NOVEC 1230 Size: 13.93 litre
Max. Protected Volume 16.3m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 600 A M Stored Pressure Type NOVEC 1230 Size: 13.93 litre
Max. Protected Volume 17m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 625 A M Stored Pressure Type NOVEC 1230 Size: 13.93 litre
Max. Protected Volume 17.7m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 650 A M Stored Pressure Type NOVEC 1230 Size: 13.93 litre
Max. Protected Volume 18.4m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 675 A M Stored Pressure Type NOVEC 1230 Size: 13.93 litre
Max. Protected Volume 19.1m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 700 A M Stored Pressure Type NOVEC 1230 Size: 17.21 litre
Max. Protected Volume 19.8m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 725 A M Stored Pressure Type NOVEC 1230 Size: 17.21 litre
Max. Protected Volume 20.5m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 750 A M Stored Pressure Type NOVEC 1230 Size: 17.21 litre
Max. Protected Volume 21.2m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 775 A M Stored Pressure Type NOVEC 1230 Size: 17.21 litre
Max. Protected Volume 21.9 Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 800 A M Stored Pressure Type NOVEC 1230 Size: 17.21 litre
Max. Protected Volume 22.6m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 825 A M Stored Pressure Type NOVEC 1230 Size: 17.21 litre
Max. Protected Volume 23.4 Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 850 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre
Max. Protected Volume 24.1m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 875 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre
Max. Protected Volume 24.8m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- 'FIRE-HAWK' Model: NFD 900 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 25.5m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 925 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 26.2m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 950 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 26.9m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 975 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 27.6m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1000 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 28.3m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1025 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 29m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1050 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 29.7m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1075 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 30.4m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1100 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 31.1m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1125 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 31.9m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1150 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 32.6m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1175 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 33.3m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1200 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 34 Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1225 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 34.7m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1250 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 35.4m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1275 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 36.1m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1300 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 36.8m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1325 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 37.5m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1350 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 38.2m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- 'FIRE-HAWK' Model: NFD 1375 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 38.9m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1400 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 39.6m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1425 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 40.3m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1450 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 41.1m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1475 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 41.8m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1500 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 42.5m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1525 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 43.2m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1550 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 43.9m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1575 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 44.6m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1600 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 45.3m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1625 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 46m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1650 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 46.7m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1675 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 47.4m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1700 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 48.1m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1725 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 48.8m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1750 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 49.6m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1775 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 50.3m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'FIRE-HAWK' Model: NFD 1800 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 51m³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFG 25 A M Stored Pressure Type NOVEC 1230 Size: 0.62 litre Max. Protected Volume 25ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFG 50 A M Stored Pressure Type NOVEC 1230 Size: 1.72 litre Max. Protected Volume 50ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- 'SEA-FIRE' Model: NFG 75 A M Stored Pressure Type NOVEC 1230 Size: 1.72 litre Max. Protected Volume 75ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFG 100 A M Stored Pressure Type NOVEC 1230 Size: 2.23 litre Max. Protected Volume 100ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFG 125 A M Stored Pressure Type NOVEC 1230 Size: 4.1 litre Max. Protected Volume 125ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFG 150 A M Stored Pressure Type NOVEC 1230 Size: 4.1 litre Max. Protected Volume 150ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFG 175 A M Stored Pressure Type NOVEC 1230 Size: 4.1 litre Max. Protected Volume 175ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFG 200 A M Stored Pressure Type NOVEC 1230 Size: 4.1 litre Max. Protected Volume 200ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMG 25 Stored Pressure Type NOVEC 1230 Size: 0.62 litre Max. Protected Volume 25ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMG 50 Stored Pressure Type NOVEC 1230 Size: 1.72 litre Max. Protected Volume 50ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMG 75 Stored Pressure Type NOVEC 1230 Size: 1.72 litre Max. Protected Volume 75ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMG 100 Stored Pressure Type NOVEC 1230 Size: 2.23 litre Max. Protected Volume 100ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMG 125 Stored Pressure Type NOVEC 1230 Size: 4.1 litre Max. Protected Volume 125ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMG 150 Stored Pressure Type NOVEC 1230 Size: 4.1 litre Max. Protected Volume 150ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMG 175 Stored Pressure Type NOVEC 1230 Size: 4.1 litre Max. Protected Volume 175ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMG 200 Stored Pressure Type NOVEC 1230 Size: 4.1 litre Max. Protected Volume 200ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 225 A M Stored Pressure Type NOVEC 1230 Size: 6.23 litre Max. Protected Volume 225ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 250 A M Stored Pressure Type NOVEC 1230 Size: 6.23 litre Max. Protected Volume 250ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 275 A M Stored Pressure Type NOVEC 1230 Size: 6.23 litre Max. Protected Volume 275ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 300 A M Stored Pressure Type NOVEC 1230 Size: 6.23 litre Max. Protected Volume 300ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 325 A M Stored Pressure Type NOVEC 1230 Size: 8.52 litre Max. Protected Volume 325ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 350 A M Stored Pressure Type NOVEC 1230 Size: 8.52 litre Max. Protected Volume 350ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 375 A M Stored Pressure Type NOVEC 1230 Size: 8.52 litre Max. Protected Volume 375ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 400 A M Stored Pressure Type NOVEC 1230 Size: 8.52 litre Max. Protected Volume 400ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 425 A M Stored Pressure Type NOVEC 1230 Size: 10.65 litre Max. Protected Volume 425ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- 'SEA-FIRE' Model: NFD 450 A M Stored Pressure Type NOVEC 1230 Size: 10.65 litre Max. Protected Volume 450ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 475 A M Stored Pressure Type NOVEC 1230 Size: 10.65 litre Max. Protected Volume 475ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 500 A M Stored Pressure Type NOVEC 1230 Size: 10.65 litre Max. Protected Volume 500ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 525 A M Stored Pressure Type NOVEC 1230 Size: 10.65 litre Max. Protected Volume 525ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 550 A M Stored Pressure Type NOVEC 1230 Size: 13.93 litre Max. Protected Volume 550ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 575 A M Stored Pressure Type NOVEC 1230 Size: 13.93 litre Max. Protected Volume 575ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 600 A M Stored Pressure Type NOVEC 1230 Size: 13.93 litre Max. Protected Volume 600ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 625 A M Stored Pressure Type NOVEC 1230 Size: 13.93 litre Max. Protected Volume 625ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 650 A M Stored Pressure Type NOVEC 1230 Size: 13.93 litre Max. Protected Volume 650ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 675 A M Stored Pressure Type NOVEC 1230 Size: 13.93 litre Max. Protected Volume 675ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 700 A M Stored Pressure Type NOVEC 1230 Size: 17.21 litre Max. Protected Volume 700ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 725 A M Stored Pressure Type NOVEC 1230 Size: 17.21 litre Max. Protected Volume 725ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 750 A M Stored Pressure Type NOVEC 1230 Size: 17.21 litre Max. Protected Volume 750ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 775 A M Stored Pressure Type NOVEC 1230 Size: 17.21 litre Max. Protected Volume 775ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 800 A M Stored Pressure Type NOVEC 1230 Size: 17.21 litre Max. Protected Volume 800ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 825 A M Stored Pressure Type NOVEC 1230 Size: 17.21 litre Max. Protected Volume 825ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 850 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 850ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 875 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 875ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 900 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 900ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 925 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 925ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 950 M Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max. Protected Volume 950ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- 'SEA-FIRE' Model: NFD 1700 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1700ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 1725 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1725ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 1750 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1750ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 1775 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1775ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NFD 1800 M Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1800ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 225 Stored Pressure Type NOVEC 1230 Size: 6.23 litre Max. Protected Volume 225ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 250 Stored Pressure Type NOVEC 1230 Size: 6.23 litre Max. Protected Volume 250ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 275 Stored Pressure Type NOVEC 1230 Size: 6.23 litre Max. Protected Volume 275ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 300 Stored Pressure Type NOVEC 1230 Size: 6.23 litre Max. Protected Volume 300ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 325 Stored Pressure Type NOVEC 1230 Size: 8.52 litre Max. Protected Volume 325ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 350 Stored Pressure Type NOVEC 1230 Size: 8.52 litre Max. Protected Volume 350ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 375 Stored Pressure Type NOVEC 1230 Size: 8.52 litre Max. Protected Volume 375ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 400 Stored Pressure Type NOVEC 1230 Size: 8.52 litre Max. Protected Volume 400ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 425 Stored Pressure Type NOVEC 1230 Size: 10.65 litre Max. Protected Volume 425ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 450 Stored Pressure Type NOVEC 1230 Size: 10.65 litre Max. Protected Volume 450ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 475 Stored Pressure Type NOVEC 1230 Size: 10.65 litre Max. Protected Volume 475ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 500 Stored Pressure Type NOVEC 1230 Size: 10.65 litre Max. Protected Volume 500ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 525 Stored Pressure Type NOVEC 1230 Size: 10.65 litre Max. Protected Volume 525ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 550 Stored Pressure Type NOVEC 1230 Size: 13.93 litre Max. Protected Volume 550ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 575 Stored Pressure Type NOVEC 1230 Size: 13.93 litre Max. Protected Volume 575ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 600 Stored Pressure Type NOVEC 1230 Size: 13.93 litre Max. Protected Volume 600ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 625 Stored Pressure Type NOVEC 1230 Size: 13.93 litre Max. Protected Volume 625ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 650 Stored Pressure Type NOVEC 1230 Size: 13.93 litre Max. Protected Volume 650ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 675 Stored Pressure Type NOVEC 1230 Size: 13.93 litre Max. Protected Volume 675ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 700 Stored Pressure Type NOVEC 1230 Size: 17.21 litre Max. Protected Volume 700ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 725 Stored Pressure Type NOVEC 1230 Size: 17.21 litre Max. Protected Volume 725ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 750 Stored Pressure Type NOVEC 1230 Size: 17.21 litre Max. Protected Volume 750ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 775 Stored Pressure Type NOVEC 1230 Size: 17.21 litre Max. Protected Volume 775ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 800 Stored Pressure Type NOVEC 1230 Size: 17.21 litre Max. Protected Volume 800ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- 'SEA-FIRE' Model: NMD 825 Stored Pressure Type NOVEC 1230 Size: 17.21 litre Max.
Protected Volume 825ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 850 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 850ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 875 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 875ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 900 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 900ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 925 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 925ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 950 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 952ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 975 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 975ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1000 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 1000ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1025 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 1025ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1050 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 1050ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1075 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 1075ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1100 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 1100ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1125 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 1125ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1150 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 1150ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1175 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 1175ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1200 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 1200ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1225 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 1225ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1250 Stored Pressure Type NOVEC 1230 Size: 26.2 litre Max.
Protected Volume 1250ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1275 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max.
Protected Volume 1275ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1300 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max.
Protected Volume 1300ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1325 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max.
Protected Volume 1325ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1350 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max.
Protected Volume 1350ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1375 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max.
Protected Volume 1375ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1400 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max.
Protected Volume 1400ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1425 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max.
Protected Volume 1425ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1450 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max.
Protected Volume 1450ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1475 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max.
Protected Volume 1475ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1500 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max.
Protected Volume 1500ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1525 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max.
Protected Volume 1525ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)

淨劑滅火器——續

CLEAN AGENT TYPE EXTINGUISHERS—Contd.

- 'SEA-FIRE' Model: NMD 1550 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1550ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1575 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1575ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1600 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1600ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1625 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1625ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1650 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1650ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1675 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1675ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1700 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1700ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1725 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1725ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1750 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1750ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1775 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1775ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)
- 'SEA-FIRE' Model: NMD 1800 Stored Pressure Type NOVEC 1230 Size: 37.7 litre Max. Protected Volume 1800ft³ Remark: Class B Fire only. (Approval Expiry Date: 1.1.2026)

Walter Kidde, The Fire Extinguishing Company, 1394 South Third Street, Mebane, North Carolina 27302, U.S.A.

- Model: FW100 FM200 Size: 1.79 kilogram Max. Protected Volume 2.8m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)
- Model: FW125 FM200 Size: 2.24 kilogram Max. Protected Volume 3.5m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)
- Model: FW200 FM200 Size: 3.59 kilogram Max. Protected Volume 5.6m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)
- Model: FW275 FM200 Size: 4.9 kilogram Max. Protected Volume 7.8m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)
- Model: FW400 FM200 Size: 7.18 kilogram Max. Protected Volume 11.3m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)
- Model: FW50 FM200 Size: 0.896 kilogram Max. Protected Volume 1.4m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)
- Model: FW500 FM200 Size: 8.98 kilogram Max. Protected Volume 14.2m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)
- Model: FW750 FM200 Size: 13.47 kilogram Max. Protected Volume 21.2m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)
- Model: FW950 FM200 Size: 17.06 kilogram Max. Protected Volume 27m³ Remark: FM-200 (Approval Expiry Date: 1.1.2026)